

## **FIRE SYSTEMS PLAN SUBMITTAL**

The Tucson Fire Department requires separate, deferred submittals for fire protection systems, including fire sprinkler and fire alarm installations, fire sprinkler underground installations, and kitchen exhaust hood fire suppression systems. The department also requires a submittal for work performed on above ground and under ground fuel storage tanks.

A permit is required for all fire protection work. If the work is limited to relocation five (5) or less sprinkler heads, only a permit is needed. If any sprinkler heads are added, or the number of sprinklers relocated exceed five (5), plans and permits are necessary.

A fire sprinkler submittal consist of three (3) copies of shop drawings, one (1) completed permit application, and one set of hydraulic calculations, if relevant. Material cut sheets should be included for any unusual parts of materials. The same requirements exist for fire alarm submittals, plus the battery calculations.

Plans can be dropped off at 300 S Fire Central Place, between 8:00 a.m. and 5:00 p.m. Permit applications can be picked up at the same address.

Water plans also may be dropped off at 300 S. Fire Central Place. If greater than a one half reduction in Appendix B flow is requested, sprinkler criteria must be submitted for all the structures on the site.